International Journal of Trend in Scientific Research and Development (IJTSRD) Volume 3 Issue 5, August 2019 Available Online: www.ijtsrd.com e-ISSN: 2456 - 6470

Analysis of on Load Tap Changing Transformer for Substation

Zin Wah Aung, Aung Thike

Lecturer, Electrical Power Department, Technological University, Mandalay, Myanmar

How to cite this paper: Zin Wah Aung | Aung Thike "Analysis of on Load Tap Changing Transformer for Substation"

Published in International Journal of Trend in Scientific Research and Development (ijtsrd), ISSN: 2456-6470, Volume-3 | Issue-5, August 2019,



pp.1144-1146, https://doi.org/10.31142/ijtsrd26556

Copyright © 2019 by author(s) and International Journal of Trend in Scientific Research and Development Journal. This is an Open Access article distributed

under the terms of Creative the **Commons Attribution**



License (CC BY 4.0) (http://creativecommons.org/licenses/by /4.0)

ABSTRACT

On-load tap changing transformers play important roles in any modern power system since they allow voltages to be maintained at desired levels despite load changes. Traditionally, on-load tap changer is a complex mechanical device, which has some deficiencies. On-load tap changer of a transformer is presented, which can eliminate excessive conduction losses and suppress the arcing in the diverter switch, which is inherent in traditional on-load transformer tap changers. The OLTC provides uninterrupted voltage is regulation of transformers under load. The transformer is equipped with a tapped winding whose tapping's are connected with the tap selector of the OLTC. Most of the current commercially available automatic voltage regulators, just measure the low voltage side of the power transformer in order to control OLTC position. In this to improve tap-changer control in order to perform properly also during a stressed situation in the 230/33 kV regulating power transformer for the substation.

KEYWORDS: load changes, tap changer, diverter switch, voltage regulation, power transformer for substation

INTRODUCTION 1.

A tap changer is a mechanism in transformers which allows for variable turn ratios to be selected in discrete steps. Transformers with this mechanism obtain this variable turn ratio by connecting to a number of access points known as taps along either the primary or secondary winding.

These systems usually posses 33 taps (one at the centre "Rated energized), known as on-load tap changing. During offload tap and sixteen to increase and decrease the turn ratio) arc tap changing, the transformer is completely de-energized, in and allow for ±8% variation (each step proving 1.65% or order to avoid arcing at the point of breath.

variation) from the nominal transformer rating which, in

Tap changers are often placed on the high voltage (low current) transformer winding for easy access and to minimize the current load during operation. ON-Load Tap Change: Most of the Generating Station, Substation system having Power Transformer with On-Load Tap Changer (OLTC). Not only in Generating Station Transformer but also in Distribution Class Transformer too. In this substation, there are three windings; such as primary winding, secondary winding and tertiary winding. Among them, we will neglect the tertiary winding which is used for residential houses.

2. LITERATURE REVIEW

Transformers are essential for the transmission, distribution, and utilization of alternating current electrical energy. In more technical terms, a power transformer is composed of two or more windings which, by electromagnetic induction, transform a system of alternating voltage and current into another system of voltage and current for the purpose of transmitting electrical power. Mainly the regulation of voltage is achieved by altering the ratio of transformation by tapping the winding, so as to alter the number of turns. The process of altering the ratio of transformation by tapping the windings is termed as tap changing. Tapping may be changed mainly in two different ways; When the transformer is disconnected from the supply, called as, offload tap changing. When the transformer is operating on load (without de-

turn, along for stepped voltage regulation of the output. N: 245 The method of offload tap changing is not suitable for large power supply systems. This system call for power transformer with a voltage regulating winding, the tapping of which are changed over under loaded condition by on-load tap changer. The schemes employed for on-load tap changer involved the use of more complicated and expensive tap changing equipment. As such, power transformers with on-load tap changing arrangement are larger in size, have a greater height and consequently more costly compared to the transformer of same output and voltage, but provided with off-load tap changer. Due to the higher cost of the on-load tap changer, normally small and medium rating of transformers is provided with off-load tap changer. Larger rating transformers are provided with on-load tap changer because frequent discontinuity of power cannot be tolerated by the power system network.

3. **STUDYING** DESIGN THEORY OF OLTC TRANSFORMER

For design and calculation of on-load tap changing transformer are calculated by using the following equations.

e.m.f per turns,

$$E_t = K \sqrt{\frac{kVA}{phase}} (2)$$

 $E_t = 4.44 f B_m A_i$ (1)

International Journal of Trend in Scientific Research and Development (IJTSRD) @ www.ijtsrd.com eISSN: 2456-6470

Table1. Values of Factor, K			
Type of Transformer	Factor, K		
Three phase core type (power)	0.6 to 0.7		
Three phase core type (distribution)	0.45 to 0.5		
Three phase shell type	1.2 to 1.3		
Single phase core type	0.75 to 0.8		
Single phase shell type	1 to 1.1		

 $A_i = k_s A_{gi}$ (3)

 k_s = stacking factor, usual value is 0.85 – 0.9

Output equation of three phase transformer Q=3.33 f $B_m \delta k_i A_w A_i \times 10^{-3}$ (kVA) (4)

 $\eta = \frac{\text{Output power}}{\text{Output powe+Total losses}} \times 100 \% (5)$

Number of turns per phase, $T_1 = T_2 \times \frac{V_1}{V_2}$ (6)

3.1 Specific Magnetic loading, B_m

Normally two types of sheet steel are used for the core and yoke of transformers

A. hot rolled silicon steel.

B. cold rolled grain oriented silicon steel.

Using hot rolled silicon steel.

Power transformers	-1.2 to 1.4 Tesla
Distribution transformers	- 1.1 to 1.3 Tesla

Using hot rolled silicon steel.Power transformers-1.5 to 1.7 TeslaDistribution transformers-1.4 to 1.5 TeslaWindow space factor $K_w = \frac{10}{30+kV1}$

Table 2.Window Space Factor k_w

kVA	3.3kV	11kV	33kV	110kV
100	0.27	0.2	0.14	200
1000	0.38	0.28	0.2	0.15
2000	0.4	0.3	0.24	0.16
5000	0.42	0.34	0.26	0.18
10000	0.45	0.37	0.29	0.2

Effects of kVA rating on the above value of window space are the following facts.

- 1. The above values are quite satisfactory for transformers between 50 to 250 kVA.
- 2. The above values may be reduced by 5 to 20% for transformers rated between 5kVA to 50kVA.
- 3. The above value may be increased by 5 to 20% for transformer above 250 kVA.

The net cross-sectional area of the core

3.2 Current Density, δ

The current density for H.V winding should be taken comparatively higher, compared to the current density for L.V winding, because cooling conditions are better in the L.V winding. Distribution transformers-2.00 to 2.5 A/mm²Power transformers- 2.3 to 3.5 A/mm²Large transformers with forced-3 to 4.5 A/mm²

Area of the window A_w=L(D-d)

Width of the window b_w= (D-d)for various stepped core

The overall length of the yoke, W= 2D+0.9d (for three-phase, three stepped)

Area of yoke $A_y 1.1$ to $1.15A_i$

Width of the yoke b_v= 0.9 d(for three stepped core)

4. SPECIFICATIONS TO DESIGN

A design based on the following typical specifications. Rating -100MVA No. of phase -Three phase Frequency -50Hz -230/33kV at no-load Voltage ratio Percentage tapping -±8×1.65% -17 positions No. of tapping -HV star, LV star Connection -Oil natural air natural (ONAN) Cooling Type -Core type, cold-rolled silicon steel sheet -Outdoor Location

TRANSFORMER

Total iron losses =0.2 % (within limit)

The iron losses in small transformer may be of the order of 0.5 to 1 % of rated output. In large and small transformers, iron losses should be within 0.2 to 0.5 % of rated output.

Percentage no-load current =0.53% (within limit)

The no-load current of a small transformer may be of the order of 3 to 5 percent of the rated current, whereas in medium transformers, it varies from 1 to 3 percent. In the case of large transformers, no-load current may be from 0.5 to 2 percent of the rated current within the proper range.

Tapping result

Rated tap and sixteen to increase and decrease the turn ratio and allow for Rated tap and sixteen to increase and decrease the turn ratio and allow for $\pm 8\%$ variation (each step proving 1.65% variation) from the nominal transformer rating which, in turn, along for stepped voltage regulation of the output.

Efficiency

At full load (0.8 p.f) = 99% (within limit) At full load (unity) = 99% (within limit) At half load (0.8 p.f) = 98.8% (within limit) At 3 load (0.8 p.f) = 99.2% (within limit)

The efficiency of the small transformer may be of the order of 98%, whereas for medium and large transformer, its values are from 98.0 to 99.2%

International Journal of Trend in Scientific Research and Development (IJTSRD) @ www.ijtsrd.com eISSN: 2456-6470

Table3. OLTC Positions for 230kV Side of 100MVA

Power Transformer							
Тар	Tan	Number of	H.V Side				
Position	гар	turns(turns)	Voltage(Volts)				
1	1.65%	2408	260360				
2	3.30%	2363	256565				
3	4.95%	2320	252770				
4	6.60%	2280	248975				
5	8.25%	2238	245180				
6	9.90%	2200	241385				
7	11.55%	2162	237590				
8	13.20%	2126	233765				
9	0%	2090	230000				
10	-1.65%	2057	226205				
11	-3.30%	2024	222410				
12	-4.95%	1992	218615				
13	-6.60%	1961	214820				
14	-8.25%	1931	211025				
15	-9.90%	1902	207230				
16	-11.55%	1874	203435				
17	-13.2%	1847	199640				

6. CONCLUSIONS

This thesis was intended for design calculation of OLTC power transformer. OLTC theory, operation and example application with Myaukpyin Substation is also described in this thesis. Presently available technical solutions enable the production of OLTCs that are reliable and meet the same life expectancy as transformers. At the percent time and for the foreseeable future, the proper implementation of the vacuum switching technology in OLTCs provides the best formula of quality, reliability, and economy achievable a maintenance-free design.

7. ACKNOWLEDGMENTS

The author deeply wants to express special appreciation and heart-left thanks to Dr. Yadana Aung, Professor and Head the Department of Electrical Power Engineering, Technological University (Mandalay) for her willingness to share her ideas and helpful suggestions on this paper writing.

8. REFERENCES

- [1] [13Die] Dieter Dohnal, Dr.: On-Load Tap Changers for Power Transformers, MR knowledge base, Maschinenfabrik Reinhausen GmbH in Regensburg, Germany, 2013, www.reinhausen.com
- [2] [12Han] Hans Linder: On-Load Tap Changer, Type UC, Technical Guide, Power and productivity, ABB AB Components, SE-771 (80) LUDVIKA, Sweden, (2012)
- [3] [1 1Ele] ABB Elektrik Sanayi A.S.: Power Transformers, Reference and application, Turkey, 2011, www.abb.com/tr
- [4] [11 Smi] Dr. J. J. Smith: On-Load Tap Changer Diagnosis on High-Voltage Power Transformer using Dynamic Resistance Measurements, Technische Universiteit Delft, Switzerland, (2011)
- [5] [04Die] Dieter Dohnal: On-Load Tap Changers for Power Transformers, A Technical Digest, MR Publicatin, (2004)
- [6] [01Ano] Anonymous: Oil-type Power Transformers, ABB Power Technology Products, Switzerland 2001, www.abb.com Limited, McGraw- Hill Publishing Company Limited,
- Able a [7] [96Mit] Mittle, V.N. And Arvind Mittal.: Design of Research an Electrical Machine, 5th Edition, Dtandard Publishers Developmen Distrbutors, (1996)